

ADDENDUM NO. 2

ROCK RIVER WATER RECLAMATION DISTRICT 2017-2018 Sanitary Sewer Lining, Contract B Capital Project No. 1855 IEPA Project No. L17-5477

This Addendum Number 2, dated May 18, 2017, for the above referenced project, supersedes all contrary and conflicting information in the specifications and contract documents, which are hereby supplemented or revised as follows:

PROJECT SPECIFICATIONS

Section II Detailed Specifications

1. Add the following Section, Section 15 –Off-site Service Reinstatement:

15 Off-site Service Reinstatement

15.1 General

1. As directed by the District, the Contractor shall reinstate existing 4" or 6" diameter sewer services on 8" through 15" lined sewers at the main on offsite lined sewer mains that are not part of this project.
2. The Contractor shall re-establish service connections to 100% of the original opening per the Sewer Service Reinstatement section of the specifications. **All sewer services reinstated shall be smoothed with a wire brush upon reinstatement.**
3. The District will provide a minimum of forty-eight (48) hours advance notice for services to be reinstated. The District shall provide a service location map and indicate the location of the service from the upstream manhole.
4. This work shall include sewer flow control in the main as required to reinstate the sewer service.
5. This work shall include routine traffic control in low traffic areas as required to reinstate the sewer service. Should implementation of traffic control measures including permits, traffic control plans, detour routes, etc. be required in high traffic areas the District will pay for traffic control based on the unit price each for Traffic Control, Complete.
6. The Contractor shall utilize the pan & tilt feature of the T.V. camera to document the service reinstatement. Site inspection at the time of reinstatement or a video documenting the reinstatement per the Television Inspection section of the specifications will be required.


15.2 Payment

Payment for Off-site Sewer Service Reinstatement shall be made based on the contract unit price for each Off-site Supplemental Sanitary Sewer Service Reinstated.

This information shall be taken into consideration when preparing your bid. This addendum will be E-mailed to all plan holders as well as posted to the District's website at www.rrwr.district.il.us.

END OF ADDENDUM NO. 2

Issued May 18, 2017
Rock River Water Reclamation District



Christopher T. Baer, P.E.
Engineering Manager