

ADDENDUM NO. 1

ROCK RIVER WATER RECLAMATION DISTRICT Machesney Park Pump Station Standby Generator Capital Project No. 96-1826

This Addendum Number 1, dated July 18, 2017, for the above referenced project, supersedes all contrary and conflicting information in the specifications and contract documents, which are hereby supplemented or revised as follows:

PROJECT SPECIFICATIONS

Section 3, Detailed Specifications, Part 3.3.F Accessories

1. Delete the second bullet point regarding the sound attenuated weather housing and replace with the following:
 - a. A sound attenuated weather housing. The housing shall be constructed of pre painted galvanized steel to resist corrosion. The maximum sound level shall not exceed 74 dBA at a distance of 23 feet. The housing shall be cleaned, phosphated, and electrocoat painted inside and out with rust inhibiting primer and exterior coating. The exterior coating shall be the manufacturer's standard color. The side panels shall be lockable and easily removed for servicing enclosed equipment.

This information shall be taken into consideration when preparing your bid. This addendum will be E-mailed to all plan holders as well as posted to the District's website at www.rrwrd.dst.il.us.

END OF ADDENDUM NO. 1

Issued July 18, 2017

Rock River Water Reclamation District



Christopher T. Baer, P.E.
Engineering Manager